



TIPS / NOTES

- 1) MINIMUM CAT 5 CABLE - ENSURE CABLES ARE PLUGGED INTO BRANCH PORTS OF ROOM MANAGERS - DO NOT CONNECT TO SMARTNET OR SMARTPACKS
- 2) ADDRESS DISPLAY - IF DEVICE HAS COMMUNICATION "AC" WILL BE SHOWN
- 3) DMX INPUT (CABLE RAN FROM DMX CONSOLE OR CONTROLLER) - RECOMMEND CABLING MEET DMX 512 ELECTRICAL SPECIFICATIONS - ENSURE POLARITY IS CORRECT
- 4) DMX OUTPUT (CABLE RAN TO LIGHT FIXTURES) - RECOMMEND CABLING MEET DMX 512 ELECTRICAL SPECIFICATIONS - ENSURE POLARITY IS CORRECT
- 5) COMMUNICATION LEDS FLASH RED/GREEN IF THIS IS NO COMMUNICATION WITH DEVICE